

MULTI INDOOR UNITS COMBINATION RULE

Multi Outdoor Unit		Available Indoor	Standard Combination					Limit
				Two units	Three units	Four units	Five units	
1 drive 2	18K- 2 Zone	Wall mounted(Oasis):9K/12K; Cassette/Duct/Console: 9K/12K;	wall mounted 9+9; Duct: 9+9	9+9				
				9+12				
				12+12				
1 drive 3	27K- 3 Zone	Wall mounted(Oasis): 9K/12K/18K; Cassette/Duct/Console&Floor Ceiling:9K/12K/18K;	mounted 9+9+9; Duct: 9+9+9	9+9	9+9+9			
				9+12	9+9+12			
				9+18	9+9+18			
				12+12	9+12+12			
				12+18	12+12+12			
				18+18				
1 drive 4	36K- 4 Zone	Wall mounted(Oasis): 9K/12K/18K/24K; Cassette/Duct/Console&Floor /12K/18K/24K; AHU:24K	wall mounted 9+9+9+9; Duct: 9+9+9+9	9+18	9+9+9	9+9+9+9		
				9+24	9+9+12	9+9+9+12		
				12+12	9+9+18	9+9+9+18		
				12+18	9+9+24	9+9+12+12		
				12+24	9+12+12	9+9+12+18		
				18+18	9+12+18	9+12+12+12		
					9+18+18	12+12+12+12		
					12+12+12			
					12+12+18			
					12+18+18			
	12+12+24							
				9+24	9+9+18	9+9+9+9	9+9+9+9+9	
				12+24	9+9+24	9+9+9+12	9+9+9+9+12	
				18+18	9+12+12	9+9+9+18	9+9+9+9+18	

1 drive 5	48K	Wall mounted(Oasis): 9K/12K/18K/24K; Cassette/Duct/Console&Floor Ceiling: 9K/12K/18K/24K; AHU: 24K	wall mounted 9+9+9+9+12; Duct: 9+9+9+9+12	18+24	9+12+18	9+9+9+24	9+9+9+9+24
				24+24	9+12+24	9+9+12+12	9+9+9+12+12
					9+18+18	9+9+12+18	9+9+9+12+18
					9+18+24	9+9+12+24	9+9+9+18+18
					9+24+24	9+9+18+18	9+9+12+12+12
					12+12+12	9+9+18+24	9+9+12+12+18
					12+12+18	9+12+12+12	9+12+12+12+12
					12+12+24	9+12+12+18	9+12+12+12+18
					12+18+18	9+12+12+24	12+12+12+12+12
					12+18+24	9+12+18+18	
					12+24+24	9+18+18+18	
					18+18+18	12+12+12+12	
					18+18+24	12+12+12+18	
						12+12+12+24	
		12+12+18+18					

Notes: The above match rules are subject to the followings:

Outdoor unit capacity shall be equal or greater than the building loads(both heating and cooling)

Each Indoor unit capacity shall be equal or greater than the zone loads (both heating and cooling) of the zone serves